



Part of the AVANGRID Family

Climate Change Vulnerability Study and Resilience Plan

Working Group Meeting 2

April 17th 2023



Welcome & Introductions

Project Update

Climate Data & Asset Exposure Analysis

Sensitivity, Consequence & Potential Impact


Priority Vulnerabilities

Discussion

Next Steps

Welcome & Introductions

- Please use the **raise hand function** at any point during the presentation to ask a question or add it to the chat.
- The meeting will be recorded
- The presentation was provided to everyone in advance of today's working group session.
- If you have technical difficulties or need assistance with the Microsoft Teams please message jeffrey.meek@icf.com



Team

- **Project Lead:** Dave Bradt, Senior Director – Strategic Planning
- **Technical Lead:** Ed Roedel, Principal Engineer – Strategic Planning
- **Stakeholder Engagement:** Dave Gridley, Director – Government & Community Relations
- **Regulatory Lead:** Lori Cole, Manager – Regulatory & Tariffs
- **Study Support:** ICF Consulting
 - Judsen Bruzgul – Project Lead
 - Dan Bishop, PhD – Climate Scientist
 - Jeffrey Meek – Stakeholder Lead



Registered Working Group Participants

Name	Organization or Affiliation
Avni Pravin	AGREE
Ziang Zhang	Binghamton University
Erika Pierce	Board of Legislators
Aimee Dailey	Broome County Planning
Beth Lucas	Broome County Planning
Owlen Huxley	C&S Companies
Brian Eden	Campaign for Renewable Energy
Barry Carr	Clean Communities of CNY
Abigail McHugh-Grifa	Climate Solutions Accelerator of the Genesee-Finger Lakes Region
Kristen Van Hooreweghe	Climate Solutions Accelerator of the Genesee-Finger Lakes Region
Molly Ryan	Clinton County IDA
Kelly Donoghue	Clinton County Office of Emergency Services
Patrice Perry	Columbia County Planning Department
Guillermo Metz	Cornell Cooperative Extension Tompkins County
Karim Beers	Cornell Cooperative Extension Tompkins County
Robert Corpora	Cortland County
Michael Mager	Couch White, LLP for Multiple Intervenors
Rick Mancini	Customized Energy Solutions
Bonnie Lawrence	Erie County Department of Environment and Planning
Romy M Fain, PhD	Heat Inverse
Michael Jagielski	Koffman Southern Tier Incubator
Andrew Brodell	Livingston County OEM
Will Gall	Livingston County OEM
Amanda Kaier	Mohawk Valley Economic Development District, Inc
Clement Chung	Monroe County Department of Environmental Services
Aferdita Bardhi	NYS Department of Public Service
Biola Daniel	NYS Department of Public Service
Bridget Frymire	NYS Department of Public Service
Eric Moore	NYS Department of Public Service
Greg Crawford	NYS Department of Public Service
Michael Richard	NYS Department of Public Service

Name	Organization or Affiliation
Moutasim Hamayel	NYS Department of Public Service
Nicole Sallèse	NYS Department of Public Service
Bob Mack	NYSERDA
Carol Chock	Raypayer and Community Intervenors
Judy McKinney Cherry	Schuyler County Partnership
Kerri Green	Schuyler County Partnership for Economic Development
Jeffrey Eisenhauer	Siemens
Jack Wheeler	Steuben County
Heather Brown	Sullivan County
Jennifer de Souza	The Raymond Corporation
Mike Straight	Tier Energy Network
Jeff Smith	Tier Energy Network, Rotary
Hailley Delisle	Tompkins County
Peter Bardaglio	Tompkins County Climate Protection Initiative
Katie Borgella	Tompkins County Dept of Planning and Sustainability
Fion MacCrea	Town of Alfred
Jason Keding	Town of Boston
Dr. Mitch Tucker	Town of Boston
Brendan Ryan	Town of Brighton
Evert Garcia	Town of Brighton
C.J. Randall	Town of Ithaca
Nick Goldsmith	Town of Ithaca
Katherine Daniels	Town of North Salem
Norma J Burris	Town of Orange
Josheph Wilson	Village of Dryden
James Basile	Village of Fair Haven
Dave McDowell	Village of Sodus Point
Thomas Lyon	Wayne County Economic Development & Planning
Ryan Dwyer	Westchester County
Brian Meyers	Wyoming County

Welcome & Introductions



Project Update

Climate Data & Asset Exposure Analysis

Sensitivity, Consequence & Potential Impact

Priority Vulnerabilities

Discussion

Next Steps

Overview of PSC Order

- March 2022, PSC law became effective (Case 22-E-0222) to NY electric utilities
- Conduct a **Climate Change Vulnerability Study (Study)** and develop a **Climate Change Resilience Plan (Plan)**
- The Study must include an evaluation of the electric grid's vulnerability to climate-driven risks
- The Plan must address the findings of the Study for the next ten- and twenty-year periods
- Engage and collaborate with stakeholders
- The Study and Plan must be filed in the fall of 2023, with updates at least every five years




Reminder: Working Group Overview

- Provide a platform for open and constructive discussion of key issues affecting NYSEG and RG&E's climate resilience planning
 - Gather input and insights from external stakeholders and subject matter experts on strengths and gaps
 - Learn about parallel efforts and connection points
- This is the second Working Group meeting, with the third meeting to be scheduled in early fall of 2023

Reminder: Efforts to Date

WG Session 1:

- Project Background (PSC Order, WG goals)
- Climate science summary & sample asset exposure findings
- Process for determining physical impacts of climate change on infrastructure
- Next steps




Reminder: Efforts to Date

WG Session 1:

- Project Background (PSC Order, WG goals)
- Climate science summary & sample asset exposure findings
- Process for determining physical impacts of climate change on infrastructure
- Next steps


What was helpful to you in the first session?



Today's Focus

- Update on the study progress since the last WG meeting
- Provide information on the climate science, assets, and exposure for the Climate Change Vulnerability Study and Resilience Plan
- Review study process for determining **sensitivity, consequence, and potential impact** of climate change on electric utility infrastructure
- Summarize the priority vulnerability findings and how they will drive the focus of the Resilience Plan
- Discuss study details and process, and share next steps

Reminder: Adaptation



Actions to increase resilience to climate change (e.g., hardening, undergrounding, new storm barriers, changes to design standards, etc.)

Welcome & Introductions

Project Update



Climate Data & Asset Exposure Analysis


Sensitivity, Consequence & Potential Impact

Priority Vulnerabilities

Discussion


Next Steps

Today's focus




Project Process Diagram

(Vulnerability Assessment → Resilience Plan)



Process Diagram: Vulnerability Assessment Overview

Potential impact scores are assessed alongside **exposure** (climate data for AVANGRID service territory) to identify **vulnerabilities**.



Overview of Preliminary Exposure Findings

High-Level


- Climate change will lead a warmer and wetter future
- Extreme events are expected to occur more frequently and of a greater intensity, but determining quantifiable changes to justify projects is difficult/uncertain

Specific

- By 2050, more than half of NYSEG and 100% of RG&E facilities are projected to go from 0 to more than 2 days per year with average temperatures over 86°F [**Affects transformers and ratings**]
- By 2050, 100% of NYSEG and RG&E facilities are projected to see 1-in-10-year temperatures ranging from 100°F to 105°F compared to just 22% currently [**Affects most temperature sensitive equipment; 104°F max**]
- By 2050, NYSEG and RG&E territories are projected to see increases of 9%-12% in the maximum 5-day precipitation event. [**Not expected to be limiting**]
- Average wind speeds are not expected to increase significantly. Windspeeds of ~70+ mph have already been measured across the territories
- There are already significant numbers of assets in flood zones for present-day 100- and 500-year events; by 2050, 100- and 500-year flood events are projected to cause deeper and more extensive flooding

Climate Pathways


- **Climate change projections:** a range of possible outcomes in terms of future temperatures, rainfall, or sea level rise
- **Vulnerability assessment scenarios:** a subset of climate projections that consider potential climate futures to characterize future climate risks
- Each scenario consists of:
 1. Shared Socioeconomic Pathway (SSP)
 2. Representative Concentration Pathway (RCP)
 - **SSP2-RCP4.5:** trends do not shift from historical patterns
 - **SSP5-RCP8.5:** rapidly growing global economy heavily dependent on fossil fuels
 3. Percentile from the range of model outcomes for a given emissions trajectory (e.g., 25th, 50th, 90th percentiles)
- We used three pathways representing the plausible lower and upper bounds of climate model projections:
 - SSP2-4.5 50th percentile as lower bound
 - **SSP5-8.5 50th percentile as high bound** ← NYSEG/RG&E's Selected Planning Level
 - SSP5-8.5 90th percentile as a high-end "stress test"




Exposure Methods

- **Exposure:** degree to which assets could face climate hazards, based on their physical locations and projected hazards
- **Climate data** is from Columbia weather stations
- **Nearest neighbor approach** created polygons for each weather station in the NYSERDA climate region
- **Assets were assigned climate data** of the polygon they're located in

NYSERDA Climate Regions and Weather Stations



Polygons created using nearest neighbor approach



Changes in this region expected to be significant




Quantifiable Climate Variables Assessed	
Annual Average Maximum Temperature	1-in-10-year Maximum Temperature
Days Per Year with Daily Avg. Temperatures > 86°F (30°C)	Days Per Year with Max. Temperatures > 95°F (35°C)
Days Per Year with Average Max. Temperatures > 104°F (40°C)	Avg. Annual Max. 5-day Precipitation
Highest Daily Peak Wind Gusts	First Street Flooding Data (100-year / 500-year)

Exposure: Temperature Findings


Key Takeaway:

All assets are projected to see more frequent days with average temperatures $>86^{\circ}\text{F}$

- Historically, assets have seen < 2 days each year with average temperatures above 86°F
- Increases projected to be highest in the southeastern region, at assets near the Mohonk and Dobbs Ferry weather stations
- Assets near the Rochester, Oswego, Buffalo, and Fredonia weather stations are also projected to see higher increases, relative to the rest of the service area, under both future scenarios



Substations




Exposure: Temperature Findings

Key Takeaway:

Assets across the service area are projected to experience higher extreme temperatures in coming decades

- Historically, RG&E and NYSEG assets have experienced 1-in-10-year temperatures ranging from 94 - 100°F
- Assets closest to the **Elmira, Dobbs Ferry, and Mohonk** weather stations are projected to experience the greatest increases in extreme temperatures
 - SSP2-4.5 50th percentile projections: 103-107°F, at these stations in 2050
 - SSP5-8.5 90th percentile projections: 108-112°F, at these stations in 2050





Exposure: Precipitation Findings

Key Takeaway:




Maximum 5-day precipitation totals are projected to increase across the service area

- Historically, assets around the **Mohonk, Dobbs Ferry, and Saratoga** weather stations have experienced the most precipitation falling during the maximum 5-day event
- Highest totals are projected to continue to occur at these **Mohonk, Dobbs Ferry, and Saratoga** weather stations

Average amount of precipitation



Change in average amount of precipitation



Exposure: Flooding Findings


Key Takeaways

There are already significant numbers of assets in flood inundation zones for present-day 100- and 500-year events; by 2050, 100- and 500-year flood events are projected to cause deeper and more extensive flooding.

Flooding was evaluated on an asset-by-asset basis, instead of a regional basis

- Currently, approximately **16%** of substations are inundated by at least ~0.5 in. of water under the 100-year storm, and **22%** are inundated under the 500-year storm
- By 2050, on average, substations are projected to see a **~2.5 in.** increase in flood depth under the 100-year storm scenario, and an **~3 in.** increase under the 500-year storm scenario

Example asset & flood data (Dannemora Distribution Station)



Exposure: Wind Findings

Quantifying the effect of climate change potential for high-winds that are the result of unique weather events is difficult to do with a high degree of confidence. Our analysis relies on:

Extreme Wind Analysis

Quantifiable

(Quantitatively Modeled Simulations)

- Average near-surface wind-speeds
- Reproduction of events experienced at regional airports via “gust-factor”
- Utilizes 16 Global Climate Models as part of NASA simulation efforts
- Does not include most extreme windspeeds, e.g., tropical cyclones

Limited “prediction” capability of maximum possible future wind-speeds

Qualified

(High Uncertainty/Dynamic Events)

- Tropical/Extra-Tropical Cyclone
 - Intensity
 - Trajectory/Path
 - Frequency
- Uses literature review of studies specific to the analyzed phenomenon





Limited to analysis from literature; cannot determine specific probabilities of storm occurrence/intensity; hard to ask “what-if” questions quantitatively

Exposure: Wind Findings

Key Takeaways:


Wind projections do not indicate large increases in average wind gust speeds in future decades; however, high impact, low likelihood storm events *are* projected to intensify, which may drive higher extreme wind speeds

- Wind gust speeds in 2050 are projected to be between **3% lower and 1% higher than historical speeds**
- Wind gusts are highest at assets around Syracuse and Albany and lowest in Plattsburgh
- Even so, future tropical/extra tropical cyclone events and other low likelihood events are projected to intensify in the future; these high intensity low likelihood events may drive higher extreme wind speeds



High Impact Low Likelihood (HILL) Extreme Event Scenarios


- Opportunity to explore “stress test” extreme weather and climate events—including consecutive or compounding events—that are not well resolved by standard downscaled climate models but drive potentially outsized impacts.
- Unlocks an expanded set and potential “worst-case” vulnerabilities to consider in the Vulnerability Assessment, including impacts to the system that may already be operating in a degraded state and complex restoration scenarios.
- NYSEG & RG&E are evaluating:
 1. Hurricane with tropical storm force winds and inland flooding
 2. Ice storm followed by cold snap



Check-in: Climate Data & Asset Exposure Analysis

Key takeaways from the
climate data & exposure
analysis?

Any questions?



Welcome & Introductions

Project Update

Climate Data & Asset Exposure Analysis



Sensitivity, Consequence & Potential Impact

Priority Vulnerabilities

Discussion

Next Steps

Sensitivity: Methods


Sensitivity: the degree to which assets could be negatively affected by exposure to a climate hazard

Each asset in scope was given a sensitivity rating for each hazard, from 0 (None) to 3 (high)

These ratings were determined using ICF in-house expertise in consultation with Avangrid Project Leads


Sensitivity	
None	<ul style="list-style-type: none">• Not sensitive to this hazard
Low	<ul style="list-style-type: none">• Asset, operation, or system faces minimal potential adverse impact from this hazard.
Moderate	<ul style="list-style-type: none">• Asset, operation, or system may be adversely affected by this hazard.• Impacts are medium by one or more factors:<ul style="list-style-type: none">• Impacts are only likely at a very high threshold of exposure (i.e., very high temperature, or water level.• Impacts are more likely to be chronic/controlled than sudden/acute (i.e., accelerated degradation rather than catastrophic failure).
High	<ul style="list-style-type: none">• Asset, operation, or system may be subject to increased risk of major and/or sudden failure in the event of hazard exposure.• Asset has limited existing tolerance for exposure to this hazard (i.e., substation without existing flood protection; non-submersible padmount transformer

Example



High Temperature				
Transmission	Sensitivity	x	Consequence	= Potential Impact
Line structures (poles/towers)	N/A	x	High	N/A
Conductors (Overhead)	Low	x	Medium	Low
Conductors (Underground)	Low	x	High	Low
Open-air current carrying components	Low	x	Medium	Low

N/A	Low	Medium	High
-----	-----	--------	------



Potential impact scores are assessed alongside **exposure** (climate data for AVANGRID service territory) to identify **priority vulnerabilities**.

These priority vulnerabilities serve as a starting point to identify and prioritize adaptation investments that will be further explored in the resilience plan.

Sensitivity: Findings



Transmission	Temperature	Wind	Inland & Riverine Flooding	Precipitation	Wind + Ice
Line structures (poles/towers)	None	High	Medium	None	High
Conductors (Overhead)	Medium	Medium	None	Low	High
Conductors (Underground)	Low	None	Low	None	None
Open-air current carrying components (i.e., switches, jumpers...)	Medium	Low	None	Low	Medium

Distribution	Temperature	Wind	Inland & Riverine Flooding	Precipitation	Wind + Ice
Structures (overhead) [includes poles]	None	High	Medium	None	High
Conductors (underground)	Low	None	Low	None	None
Conductors (overhead)	Medium	Medium	None	None	High
Transformers (overhead)	High	Low	None	None	High
Transformers (pad mount)	High	Low	High	None	Low
Regulators (pole mount)	Medium	Low	None	None	High
Capacitors (pole mount)	Medium	Low	None	None	Low
Open-air current carrying components (i.e., switches, jumpers...)	Medium	Low	None	None	Medium
Surge Arresters	Low	Low	None	Low	Medium

Substations	Temperature	Wind	Inland & Riverine Flooding	Precipitation	Wind + Ice
Substation transformers	High	Low	High	None	Medium
Substation regulators	High	Low	High	None	Medium
Circuit breakers (open air)	Medium	Low	High	None	Medium
Protection and control devices	Low	Low	High	None	Low
Instrument Transformers (CT's and PT's)	Medium	Low	High	None	Low
Control room/ Control house	Low	Low	High	None	Low
Substation Reactor	High	Low	High	None	Medium
Support Structures	None	Medium	Low	None	Medium

Sensitivity is the degree to which assets could be negatively affected by climate hazard exposures.

Consequence: Findings



Transmission	Consequences
Line structures (poles/towers)	High
Conductors (Overhead)	Medium
Conductors (Underground)	High
Open-air current carrying components (i.e., switches, jumpers...)	Medium

Distribution	Consequences
Structures (overhead) [includes poles]	Medium
Conductors (underground)	Medium
Conductors (overhead)	Low
Transformers (overhead)	Medium
Transformers (pad mount)	Medium
Regulators (pole mount)	Medium
Capacitors (pole mount)	Low
Open-air current carrying components (i.e., switches, jumpers...)	Low
Surge Arresters	Low

Substations	Consequences
Substation transformers	High
Substation regulators	High
Circuit breakers	High
Protection and control devices	Medium
Instrument Transformers (CT's and PT's)	Medium
Control room/ Control house	High
Substation Reactor	High
Support Structures	High

Consequence is the estimated magnitude of negative outcomes associated with impacts.

Potential Impact Ratings (sensitivity x consequence)



None	Low	Medium	High
------	-----	--------	------

Transmission	Temperature	Wind	Inland & Riverine Flooding	Precipitation	Wind + Ice
Line structures (poles/towers)	None	High	High	None	High
Conductors (Overhead)	Medium	Medium	None	Low	High
Conductors (Underground)	Medium	None	Medium	None	None
Open-air current carrying components (i.e., switches, jumpers...)	Medium	Low	None	Low	Medium


Distribution	Temperature	Wind	Inland & Riverine Flooding	Precipitation	Wind + Ice
Structures (overhead) [includes poles]	None	High	Medium	None	High
Conductors (underground)	Low	None	Low	None	None
Conductors (overhead)	Low	None	None	None	Medium
Transformers (overhead)	High	Low	None	None	High
Transformers (pad mount)	High	Low	High	None	Low
Regulators (pole mount)	Medium	Low	None	None	High
Capacitors (pole mount)	Low	Low	None	None	Low
Open-air current carrying components (i.e., switches, jumpers...)	Low	Low	None	None	Low
Surge Arresters	Low	Low	None	Low	Low

Substations	Temperature	Wind	Inland & Riverine Flooding	Precipitation	Wind + Ice
Substation transformers	High	Medium	High	None	High
Substation regulators	High	Medium	High	None	High
Circuit breakers	High	Medium	High	None	High
Protection and control devices	Low	Low	High	None	Low
Instrument Transformers (CT's and PT's)	Medium	Low	High	None	Low
Control room/ Control house	Medium	Medium	High	None	Medium
Substation Reactor	High	Medium	High	None	High
Support Structures	None	High	Medium	None	High

Check-in: Sensitivity, Consequence, & Potential Impacts

Major takeaways from this analysis?

Which concerns are most important to you?



Welcome & Introductions

Project Update

Climate Data & Asset Exposure Analysis

Sensitivity, Consequence & Potential Impact



Priority Vulnerabilities

Discussion

Next Steps

Vulnerabilities

The potential of assets, operations or customers to be affected by projected hazards, and the significance of the potential consequences.




Each asset was given a **sensitivity** rating for each hazard, from 0 (N/A) to 3 (high), and a **consequence** rating.



Sensitivity and consequence ratings were considered in tandem to generate a **potential impact** score from low (green) to high (red).





These ratings were determined through Avangrid and ICF experts' knowledge.



Potential impact scores were assessed alongside exposure data to create a list of **priority vulnerabilities**.

Preliminary Priority Vulnerabilities

Vulnerability is the potential of assets to be affected by projected hazards, and significance of potential consequences.



These asset-hazard-region combinations are **priority potential vulnerabilities** for further investigation in the resilience plan:

	Temperature	Wind	Inland & Riverine Flooding	Precipitation	Wind + Ice
Asset Families with highest impact ratings	Substations	Transmission Distribution Substations	Transmission Substations	N/A	Transmission Distribution Substations
Climate regions of highest hazard exposure	Brewster, Elmira	N/A	Floodplains span service area; evaluated on asset-by-asset basis	Brewster, Saratoga	N/A

Project Overview

Climate Change Vulnerability Study

Resilience Plan

Climate Science

Exposure

The degree to which assets, operations, or systems could face climate hazards, based on their physical locations and projected hazards.

Potential Impact

The potential for negative outcomes in the event of climate hazard exposure.

Sensitivity

The degree to which assets, operations, or systems could be affected by exposures.

Consequence

Estimated magnitude of negative outcomes associated with impacts. Incorporates criticality and adaptive capacity.

Vulnerability

The potential of assets or operations to be affected by projected hazards, and the significance of the potential consequences.

Resilience Framework

Comprehensive framework to address gradual climate change and extreme events that can guide investment planning

Key Planning, Design, Operations, and Emergency Response Changes

Resilience Measures for Next 10 and 20 Years

Estimated Costs and Benefits

Q2 2022

Q3 2022

Q4 2022

Q1 2023


Q2 2023

Q3 2023


Q4 2023

Check-in: Priority Vulnerabilities

Any questions about
priority vulnerabilities
findings?



Vulnerability Assessment → Risk Assessment and Resilience Plan



Welcome & Introductions

Project Update

Climate Data & Asset Exposure Analysis

Sensitivity, Consequence & Potential Impact

Priority Vulnerabilities




Discussion

Next Steps

Additional questions about methods or findings?

Anything you'd like to learn more about in the next update?



Welcome & Introductions

Project Update

Climate Data & Asset Exposure Analysis

Sensitivity, Consequence & Potential Impact

Priority Vulnerabilities

Discussion




Next Steps

Continued Stakeholder Engagement Opportunities


- Updates will continue to be provided via periodic Project Update emails in 2023.
- Next Working Group meeting will be in early Fall of 2023 to further discuss the risk assessment and provide an update on the Resilience Plan
- Continue building towards the climate vulnerability study filing (Sept 2023) and resilience plan filing (Nov 2023)
- Parties are welcome to join the Working Group at any time

Stakeholder Engagement Timeline



Stakeholder Engagement Timeline

Key takeaway from today?





Thank You!

Please send any follow up questions or comments to:
nyseg.rge.publicaffairs@avangrid.com