

RGE QUALIFYING UPGRADE DISCLOSURE					
Substation	Upgrade	Planning Grade Estimate	Incremental Hosting Capacity (MW)	Percentage Received	Milestone Schedule*
S70	3V0 Installation	\$676,057	16.66	30%	18 months
S120	3V0 Installation	\$642,906	3.16	0%	
S124	3V0 Installation	\$419,702	16.8	0%	
S127	3V0 Installation	\$697,257	11.2	0%	
S127	Distribution Line Upgrade	\$1,837,443	9.8	0%	
S127	Substation Transformer	\$4,688,213	11.2	0%	
S142	3V0 Installation	\$657,954	13.28	38%	18 months
S142	3V0 Installation	\$865,537	11.3	0%	18 months
S145	Distribution Line Upgrade	\$2,228,160	9.8	0%	
S145	Substation Transformer	\$4,556,712	17.5	0%	
S145	3V0 Installation	\$674,335	6.3	96%	18 months
S168	Distribution Line Upgrade	\$4,937,473	9.8	0%	
S168	3V0 Installation	\$737,509	9.1	0%	
S180	Substation Transformer	\$8,765,977	11	0%	
S189	3V0 Installation	\$704,036	5.5	76%	18 months
S189	Distribution Line Upgrade	\$418,181	4.97	0%	
S194	3V0 Installation	\$660,480	7.2	0%	
S194	Distribution Line Upgrade	\$732,780	8.8	0%	
S195	3V0 Installation	\$704,011	1.5	0%	
S198	3V0 Installation	\$1,133,382	4.8	42%	18 months
S210	3V0 Installation	\$661,564	6.1	39%	18 months
S217	3V0 Installation	\$603,646	5.25	38%	18 months
S218	3V0 Installation	\$1,126,013	12.013	89%	18 months
S218	Distribution Line Upgrade	\$460,534	5.64	0%	
S230	3V0 Installation	\$691,985	4.9	50%	18 months
S419	Distribution Line Upgrade	\$3,158,415	9.8	0%	
S419	3V0 Installation	\$960,760	21.78	0%	
S8375	Substation Regulator	\$1,240,993	15.1	0%	
S8333	Distribution Line Upgrade	\$385,020	22.6	0%	
S8333	Substation Transformer	\$8,765,977	11	0%	

*Material lead time may impact this timeline

**Current Qualifying Upgrade Disclosure queue as of December 19, 2024